

ELECTRICAL LIGHTING GENERAL NOTES:

- MEP SPECIFICATIONS SHALL APPLY TO ALL WORK SHOWN ON THIS DRAWING UNLESS OTHERWISE NOTED.
- REFER TO THE ARCHITECTURAL REFLECTED CEILING PLAN FOR THE EXACT LOCATION OF ALL LIGHTING FIXTURES.
- THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION OF ALL JUNCTION BOXES IN THE JUNCTION BOX GRID AND AVAILABILITY OF ALL CIRCUITS INDICATED TO BE USED.
- CONTRACTOR SHALL FIELD VERIFY LOCATIONS OF ALL EXISTING EQUIPMENT PRIOR TO CONSTRUCTION. PROVIDE CIRCUIT TRACING AS REQUIRED TO DETERMINE CIRCUIT AVAILABILITY. PROVIDE A WRITTEN REPORT TO ENGINEER AND BUILDING MANAGEMENT SHOWING LIGHTING LOCATIONS AND CIRCUIT NUMBER USED.
- EGRESS AND EXIT LIGHT FIXTURES SHALL BE CONNECTED TO WITH 2#10,1/2" C. TO 90-MINUTE BATTERY PACK.
- ALL FIRE ALARM DEVICES SHALL MATCH EXISTING.
- CONTRACTOR SHALL REFER TO BUILDING MANAGEMENT'S "RULES AND REGULATIONS" TO COMPLY WITH BUILDING STANDARDS.
- FOR RETURN AIR PLENUMS, ALL MATERIALS LOCATED WITHIN A RETURN AIR PLENUM SHALL BE RATED AND APPROVED FOR INSTALLATION IN A RETURN AIR PLENUM.

ELECTRICAL POWER GENERAL NOTES:

- MEP SPECIFICATIONS SHALL APPLY TO ALL WORK ON THIS DRAWING UNLESS OTHERWISE NOTED.
- REFER TO ARCHITECT FOR EXACT HEIGHT AND LOCATION OF ALL FLOOR AND WALL OUTLETS.
- ALL DATA/TELEPHONE OUTLETS SHALL BE PROVIDED WITH PULL STRINGS.
- CONTRACTOR SHALL LOCATE ALL ELECTRICAL & TELEPHONE OUTLETS WITHIN THE LIMITS OF THE TENANT FURNITURE PLAN PROVIDED BY THE ARCHITECT. CONTRACTOR SHALL MARK INTENDED LOCATION OF ALL OUTLETS PRIOR TO INSTALLATION, THEN SHALL NOTIFY TENANT FOR APPROVAL BEFORE PROCEEDING.
- CONTRACTOR SHALL PROVIDE NEW CIRCUIT DIRECTORY CARD AT PANELS. CIRCUITS SHALL BE LABELED TO CORRESPOND TO THE CIRCUITS SHOWN ON THE DRAWINGS. CONTRACTOR SHALL CONNECT CIRCUITS AS REQUIRED TO COMPLY WITH THIS DRAWING.
- CONDUCTORS SHALL BE #12 AWG SOLID COPPER (THWN) IN 1/2" CONDUIT UNLESS OTHERWISE INDICATED.
- ALL OUTLETS TO BE MOUNTED VERTICALLY UNLESS OTHERWISE INDICATED.
- CONTRACTOR SHALL PROVIDE ONE PULL STRING FOR EACH VOICE OR DATA OUTLET SHOWN. WHEN VOICE AND DATA OUTLETS ARE SHOWN ADJACENT, CONTRACTOR SHALL PROVIDE ONE PULL STRING (WITH ONE WALL PENETRATION) FOR THE PAIR, UNLESS NOTED OTHERWISE. VOICE AND DATA LINES SHALL BE PULLED BY OTHERS.
- CONTRACTOR SHALL REFER TO BUILDING MANAGEMENT'S "RULES AND REGULATIONS" TO COMPLY WITH BUILDING STANDARDS.
- GANG TOGETHER, ALL NEW ELECTRICAL, TELEPHONE AND COMPUTER OUTLETS SHOWN ADJACENT TO EACH OTHER.
- VERIFY FINAL LOCATIONS FOR ROUGH-INS WITH FIELD MEASUREMENTS AND WITH THE REQUIREMENTS OF THE ACTUAL EQUIPMENT TO BE CONNECTED.
- COORDINATE THE INSTALLATION OF ELECTRICAL MATERIALS AND EQUIPMENT ABOVE CEILINGS WITH SUSPENSION SYSTEM, MECHANICAL EQUIPMENT AND SYSTEMS, AND STRUCTURAL COMPONENTS. COORDINATE ELECTRICAL EQUIPMENT AND MATERIALS INSTALLATION WITH OTHER BUILDING COMPONENTS.
- VERIFY MECHANICAL EQUIPMENT SWITCH AND CONNECTION REQUIREMENTS, ITEM BY ITEM, WITH THE MECHANICAL CONTRACTOR, BEFORE WIRING EQUIPMENT. RESOLVE ALL DISCREPANCIES WITHOUT FURTHER COST TO OWNER.
- FOR RETURN AIR PLENUMS, ALL MATERIALS LOCATED WITHIN A RETURN AIR PLENUM SHALL BE RATED AND APPROVED FOR INSTALLATION IN A RETURN AIR PLENUM.

LEGEND OF ELECTRICAL SYMBOLS

SYMBOL	DESCRIPTION
	FAULT CURRENT CALCULATION RESULTS.
	CONDUIT RUN CONCEALED IN WALLS OR ABOVE CEILING. ARROW INDICATES HOMERUN TO PANEL. CONDUCTOR DESIGNATIONS ARE AS FOLLOWS: LONG HATCH INDICATES NEUTRAL, SHORT HATCH INDICATES PHASE. " " INDICATES INSULATED OR ISOLATED GROUND. " " INDICATES SWITCHLEG, AND NO HATCHES INDICATES TWO CONDUCTORS.
	PARTIAL HOME RUN. SAME AS ABOVE.
	CONDUIT RUN CONCEALED IN FLOOR SLAB, BELOW FLOOR SLAB OR BELOW GRADE. WIRING SAME AS ABOVE.
	DUPLEX RECEPTACLE OUTLET; 20 AMP, 125V, 3 WIRE, GROUNDED TYPE.
	QUADRUPEX RECEPTACLE OUTLET GANGED WITH A COMMON WALL PLATE; (2)-20 AMP, 125V, 3 WIRE, GROUNDED TYPE.
	DUPLEX RECEPTACLE OUTLET WITH GROUND FAULT INTERRUPTER; 20 AMP, 125V, 3 WIRE GROUNDED TYPE.
	JUNCTION BOX MOUNTED ABOVE ACCESSIBLE CEILING.
	JUNCTION BOX
	DISCONNECT IN A NEMA 1 ENCLOSURE, UNLESS OTHERWISE SPECIFIED. REFER TO DRAWINGS FOR AMPERAGE, PHASES, & FUSE SIZE. (IF REQUIRED)
	MOTOR STARTER / DISCONNECT IN A NEMA 1 ENCLOSURE, UNLESS OTHERWISE SPECIFIED. REFER TO DRAWINGS FOR AMPERAGE, PHASES, FUSE SIZE (IF REQUIRED), AND SIZE.
	TRANSFORMER - REFER TO DRAWINGS FOR VOLTAGE AND AMPERAGE.
	SURFACE PANELBOARD W/ NEC CLEARANCES; 120/208 VOLT.
	SURFACE PANELBOARD W/ NEC CLEARANCES; 277/480 VOLT.

NOTES:
 1. ALL SYMBOLS MAY NOT BE USED ON THIS DRAWINGS.
 2. REFER TO SPECIFICATIONS FOR MOUNTING HEIGHTS

WIRELESS LIGHT SWITCHING CONTROLS

SYMBOL	DESCRIPTION
	A SINGLE LEADER CORRESPONDS TO A SINGLE SWITCH FOR THAT LIGHTING CIRCUIT. THE SWITCH WILL HAVE A CORRESPONDING AND MATCHING DESIGNATION LETTER IF THERE ARE OTHER SWITCHES IN THE SAME ROOM.
	MULTIPLE LEADERS CORRESPOND TO MULTIPLE SWITCHES FOR THAT LIGHTING CIRCUIT. THE QUANTITY OF LEADERS CORRESPONDS TO THE QUANTITY OF SWITCHES THAT CONTROL THAT CIRCUIT. THE SWITCHES WILL HAVE A CORRESPONDING AND MATCHING DESIGNATION LETTER.

RECEPTACLE CONTROL SCHEDULE

MARK	CONTROL DESCRIPTION	CONTROL DEVICES	SEQUENCE OF OPERATION
1	VACANCY SENSING SPLIT-CIRCUIT CONTROLLED	16352-1PX (20A, 125V, SPLIT-CIRCUIT MARKED CONTROLLED DUPLEX RECEPTACLE) RMJS-20R-DV-B (RECEPTACLE CONTROL POWER PACK WITH WIRELESS RECEIVER)	TOP HALF OF ALL RECEPTACLES IN THIS ROOM ARE TO BE AUTO-ON/AUTO-OFF CONTROLLED BY THE RECEPTACLE CONTROL POWER PACK RECEIVING INPUTS FROM THE LIGHTING CONTROL SENSOR IN THE ROOM, REFER TO LIGHTING PLAN. BOTTOM HALF TO REMAIN UNSWITCHED.

THIS CONTROL SCHEDULE IS INTENDED TO PROVIDE GENERAL RECEPTACLE CONTROL DEVICE QUALITY AND PERFORMANCE REQUIREMENTS ONLY. CONTRACTOR SHALL BE RESPONSIBLE TO OBTAIN THE EXACT MODEL/CATALOG NUMBER OF THE RECEPTACLE CONTROL DEVICES LISTED ABOVE. THIS RECEPTACLE CONTROL DESIGN IS BASED ON LUTRON LIGHTING CONTROL DEVICES AND LEVITON RECEPTACLES, CONTRACTOR MUST SUBMIT ANY SUBSTITUTION OF AN APPROVED MANUFACTURER TO THE ENGINEER FOR REVIEW.

LIGHTING CONTROL SCHEDULE

MARK	CONTROL DESCRIPTION	CONTROL DEVICES	SEQUENCE OF OPERATION
1	WALL MOUNTED VACANCY SENSING	MS-B102 (DUAL-TECHNOLOGY WALL VACANCY SENSOR)	LIGHT FIXTURES IN THIS ROOM ARE TO BE MANUAL-ON/ AUTO-OFF CONTROLLED BY THE WALL MOUNTED VACANCY SENSOR SWITCH.
1C	WALL MOUNTED OCCUPANCY SENSING	MS-B102 (DUAL-TECHNOLOGY WALL OCCUPANCY SENSOR)	LIGHT FIXTURES IN THIS ROOM ARE TO BE AUTO-ON/ AUTO-OFF CONTROLLED BY THE WALL MOUNTED OCCUPANCY SENSOR SWITCH.
2B	CEILING MOUNTED VACANCY SENSING	PJ2-2B-GXX-L01 (WIRELESS REMOTE SWITCH) LRF2-OCR2B-P (WIRELESS CEILING VACANCY SENSOR) RMJS-16R-DV-B (RELAY POWER PACK WITH WIRELESS RECEIVER)	LIGHT FIXTURES IN THIS ROOM ARE TO BE MANUAL-ON/ AUTO-OFF CONTROLLED BY THE RELAY POWER PACK WITH WIRELESS RECEIVER; RECEIVING INPUTS FROM THE WIRELESS CEILING MOUNTED VACANCY SENSOR & THE WIRELESS REMOTE SWITCH.
2C	CEILING MOUNTED OCCUPANCY SENSING	PJ2-2B-GXX-L01 (WIRELESS REMOTE SWITCH) LRF2-OCR2B-P (WIRELESS CEILING OCCUPANCY SENSOR) RMJS-16R-DV-B (RELAY POWER PACK WITH WIRELESS RECEIVER)	LIGHT FIXTURES IN THIS ROOM ARE TO BE AUTO-ON/ AUTO-OFF CONTROLLED BY THE RELAY POWER PACK WITH WIRELESS RECEIVER; RECEIVING INPUTS FROM THE WIRELESS CEILING MOUNTED OCCUPANCY SENSOR & THE WIRELESS REMOTE SWITCH.
4B	CEILING MOUNTED VACANCY SENSING WITH DIMMING	PJ2-2BRL-GXX-L01 (WIRELESS REMOTE SWITCH WITH DIMMING) LRF2-OCR2B-P (WIRELESS CEILING VACANCY SENSOR) RMJS-8T-DV-B (0-10V DIMMING POWER PACK WITH WIRELESS RECEIVER)	LIGHT FIXTURES IN THIS ROOM ARE TO BE MANUAL-ON/ AUTO-OFF CONTROLLED BY THE DIMMING POWER PACK WITH WIRELESS RECEIVER; RECEIVING INPUTS FROM THE WIRELESS CEILING MOUNTED VACANCY SENSOR & THE WIRELESS DIMMING REMOTE SWITCH.
6	DIMMING WITH TIMECLOCK CONTROL	PJ2-2BRL-GXX-L01 (WIRELESS REMOTE SWITCH WITH DIMMING) RMJS-8T-DV-B (0-10V DIMMING POWER PACK WITH WIRELESS RECEIVER)	LIGHT FIXTURES IN THIS ROOM ARE TO BE MANUAL-ON/ AUTO-OFF CONTROLLED BY A TIMECLOCK;& WIRELESS DIMMING REMOTE SWITCH.

THIS CONTROL SCHEDULE IS INTENDED TO PROVIDE GENERAL LIGHTING CONTROL DEVICE QUALITY AND PERFORMANCE REQUIREMENTS ONLY. CONTRACTOR SHALL BE RESPONSIBLE TO OBTAIN THE EXACT MODEL/CATALOG NUMBER OF THE LIGHTING CONTROL DEVICES LISTED ABOVE. THIS LIGHTING CONTROL DESIGN IS BASED ON LUTRON LIGHTING CONTROL DEVICES, CONTRACTOR MUST SUBMIT ANY SUBSTITUTION OF AN APPROVED MANUFACTURER TO THE ENGINEER FOR REVIEW.

LIGHT FIXTURE SCHEDULE

Label	Mounting	Lamp	Description	Luminaire Watts
A - 33W	RECESSED	LED	WILLIAMS P/N: FT-22-LS-8CS-AF-DIM-UNV - 33W@3500K	32.7
AE	RECESSED	LED	SAME AS ABOVE WITH 90-MINUTE BATTERY PACK	32.7
A1 - 24W	RECESSED	LED	WILLIAMS P/N: FT-22-LS-8CS-AF-DIM-UNV - 24W@3500K	23.8
A1E	RECESSED	LED	SAME AS ABOVE WITH 90-MINUTE BATTERY PACK	23.8
BE-30W	RECESSED	LED	WILLIAMS P/N: BP-22-LS-8CS-DIM-UNV - 30W@3500K WITH 90-MINUTE BATTERY PACK	30.5
D	RECESSED	LED	WILLIAMS P/N: 4DR-TL-L10/835-DIM-UNV-OW-OF-CS-N-F1	9
DE	RECESSED	LED	SAME AS ABOVE WITH 90-MINUTE BATTERY PACK	9
DW (EXISTING)	RECESSED	LED	HE WILLIAMS 6DR-TL-L15/835-DIM-UNV-OM-OF-CS-WET-CC-N-F1	13.8
DWE (EXISTING)	RECESSED	LED	HE WILLIAMS 6DR-TL-L15/835-DIM-UNV-OM-OF-CS-WET-CC-N-F1-EM/10	13.8
T	SURFACE	LED	LUMENTURE JT-8 TRACK WITH LUMENTURE T50-30H-11022-22-X-J HEADS	14. PROVIDE WITH 80W CURRENT LIMITER
V	SURFACE	LED	LOUIS PARISIAN 3-LIGHT MODERN CONTEMPORARY LED VANITY	4
X	SURFACE	LED	NEW EXIT SIGN T.B.D WITH 90-MINUTE BATTERY PACK	<5

THIS FIXTURE SCHEDULE IS INTENDED TO PROVIDE GENERAL LIGHTING FIXTURE QUALITY AND PERFORMANCE REQUIREMENTS ONLY. CONTRACTOR SHALL BE RESPONSIBLE TO OBTAIN THE EXACT MODEL/CATALOG NUMBER OF THE LIGHTING FIXTURES LISTED ABOVE. ANY DIFFERENCES BETWEEN THIS LIGHTING FIXTURE SCHEDULE AND ARCHITECTURAL DRAWINGS OR MANUFACTURERS PRODUCT LISTINGS SHALL BE IMMEDIATELY BROUGHT TO THE ATTENTION OF THE ENGINEER. FLUORESCENT LIGHTS THAT ARE SHOWN WITH DIMMER CONTROL SHALL BE PROVIDED WITH AN ELECTRONIC DIMMING BALLAST. FLUORESCENT LIGHTS NOT SHOWN DIMMED SHALL HAVE A NON-DIMMING ELECTRONIC BALLAST. ALL LAMPS SHALL MATCH BUILDING STANDARD.



ARCHITECTURE PLANNING INTERIOR DESIGN
 15810 PARK TEN PLACE, SUITE 300
 HOUSTON, TEXAS 77084
 713-465-4650
 www.sligroup.com



ACORN GOLF SIMULATOR
 13825 Timber Forest Dr, Houston, TX 77044
 SUITE 103

PROJECT NUMBER: 24052.00

ISSUED FOR CLIENT APPROVAL	DATE
ISSUED FOR BIDDING	04/09/2026
ISSUED FOR PERMIT	
ISSUED FOR CONSTRUCTION	

REVISIONS		
MARK	DESCRIPTION	DATE
	REVIEW SET	03/27/2026
	ISSUE FOR BID SET	04/09/2026

The information, ideas, designs, details, layouts, techniques, features, arrangements, plans, sequences, dimensions, allowances, tolerances, conceptions, specifications, intentions, technology or embodiments, as illustrated, arranged, displayed, noted, recorded, indicated, represented, disclosed, evidenced, detailed or otherwise reduced to tangible form hereon, either expressly, inherently or by implication, are the confidential and proprietary information of SLI Design, Inc. and shall not be used for any purpose other than the specific project or undertaking identified on the drawing title block or legend for which they are and have been prepared by SLI Design, Inc. Any other reproduction, disclosure or use of any portion of the confidential and proprietary information of SLI Design, Inc. shall be a breach of the obligation of confidence created by the acceptance of this drawing from SLI Design, Inc. for a specific project or Contract. Any copying, duplicating, reproducing, utilization, alteration, modification, revision or change to this drawing, is expressly prohibited unless done with the prior written consent or approval of SLI Design, Inc. and shall not be undertaken without receipt of such prior written approval. This drawing is loaned by SLI Design, Inc. for the limited purpose of complying with a specific Contract. The drawing remains the property of SLI Design, Inc. and shall be returned upon request or completion of the contract, unless specifically authorized by Contract, under which it was loaned.

DESIGN TEAM
 PM: JG
 MECHANICAL: CC
 ELECTRICAL: JG
 CHECKED-BY:

DRAWING TITLE
ELECTRICAL INFORMATION

SHEET NO.

E-1.00

EIBIE Mechanical
 Electrical
 Plumbing
 CONSULTING ENGINEERING
 154536
 12803 Southwest Freeway, Ste 170, Stafford, TX 77477
 Tel: (713) 840-0177 / Firm Reg. No: 5638

